CERTIFICATE OF ANALYSIS

Work Order	:	**KS2604214**			
Client	:	**Nicola Lakeshore Water Utility Co. Ltd.**	Laboratory	:	ALS Environmental - Kamloops
Contact	:	Kevin Rabbitt	Account Manager	:	Caitlin Fountain
Address	:	105 - 1121 McFarlane Way Merritt British Columbia Canada V1K 1B9	Address	:	1445 McGill Road, Unit 2B Kamloops BC Canada V2C 6K7
Telephone	:	250 378 4206	E-mail	:	Caitlin.Fountain@alsglobal.com
Project	:	Arsenic Plant B	Telephone	:	250 372 3588
PO	:	----	Date Samples Received	:	14-Oct-2026 10:15
C-O-C number	:	----	Date Analysis Commenced	:	21-Oct-2026
Sampler	:	Jeff Wike, Nikki Fulford	Issue Date	:	22-Oct-2026 16:52
Site	:	Nicola Lakeshore Water Utility			
Quote number	:	Nicola Lakeshore Routine Tests			
No. of samples received	:	1			
No. of samples analysed	:	1			

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QC Interpretive report to assist with Quality Review and Sample Receipt Notification (SRN).

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is conducted in accordance with US FDA 21 CFR Part 11.

Signatories	*Position*	*Laboratory Department*
Kim Jensen	Department Manager - Metals	Metals, Burnaby, British Columbia

General Comments

The analytical methods used by ALS are developed using internationally recognized reference methods (where available), such as those published by US EPA, APHA Standard Methods, ASTM, ISO, Environment Canada, BC MOE, and Ontario MOE. Refer to the ALS Quality Control Interpretive report (QCI) for applicable references and methodology summaries. Reference methods may incorporate modifications to improve performance.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

Please refer to Quality Control Interpretive report (QCI) for information regarding Holding Time compliance.

Key: CAS Number: Chemical Abstracts Services number is a unique identifier assigned to discrete substances.
LOR: Limit of Reporting (detection limit).

Unit	*Description*
mg/L	milligrams per litre

<: less than.
>: greater than.
Surrogate: An analyte that is similar in behavior to target analyte(s), but that does not occur naturally in environmental samples. For applicable tests, surrogates are added to samples prior to analysis as a check on recovery.

Test results reported relate only to the samples as received by the laboratory.
UNLESS OTHERWISE STATED on SRN or QCI Report, ALL SAMPLES WERE RECEIVED IN ACCEPTABLE CONDITION.

Analytical Results

Sub-Matrix: Water (Matrix: Water)					Client sample ID	Arsenic Plant Tank B ----	----	----	----	----
					Client sampling date / time	14-Oct-2026 07:30	----	----	----	----
Analyte	CAS Number	Method/Lab	LOR	Unit		KS2604214-001	----	----	----	----
						Result	----	----	----	----
Total Metals										
Arsenic, total	7440-38-2	E420/VA	0.00010	mg/L		0.0106	----	----	----	----

Please refer to the General Comments section for an explanation of any qualifiers detected.

ALS Canada Ltd.

right solutions.
right partner.

Quality Control Interpretive Report

Work Order	:	**KS2604214**		
Client	:	Nicola Lakeshore Water Utility Co. Ltd.	Laboratory	: ALS Environmental - Kamloops
Contact	:	Kevin Rabbitt	Account Manager	: Caitlin Fountain
Address	:	105 - 1121 McFarlane Way Merritt BC Canada V1K 1B9	Address	: 1445 McGill Road, Unit 2B Kamloops British Columbia Canada V2C 6K7
Telephone	:	250 378 4206	Telephone	: 250 372 3588
Project	:	Arsenic Plant B	Date Samples Received	: 14-Oct-2026 10:15
PO	:	----	Issue Date	: 22-Oct-2026 16:52
C-O-C number	:	----		
Sampler	:	Jeff Wike, Nikki Fulford		
Site	:	Nicola Lakeshore Water Utility		
Quote number	:	Nicola Lakeshore Routine Tests		
No. of samples received	:	1		
No. of samples analysed	:	1		

This report is automatically generated by the ALS LIMS (Laboratory Information Management System) through evaluation of Quality Control (QC) results and other QA parameters associated with this submission, and is intended to facilitate rapid data validation by auditors or reviewers. The report highlights any exceptions and outliers to ALS Data Quality Objectives, provides holding time details and exceptions, summarizes QC sample frequencies, and lists applicable methodology references and summaries.

Key

Anonymous: Refers to samples which are not part of this work order, but which formed part of the QC process lot.
CAS Number: Chemical Abstracts Services number is a unique identifier assigned to discrete substances.
DQO: Data Quality Objective.
LOR: Limit of Reporting (detection limit).
RPD: Relative Percent Difference.

Workorder Comments

Holding times are displayed as "---" if no guidance exists from CCME, Canadian provinces, or broadly recognized international references.

Summary of Outliers

Outliers : Quality Control Samples

- No Method Blank value outliers occur.
- No Duplicate outliers occur.
- No Laboratory Control Sample (LCS) outliers occur
- No Laboratory Control Sample Duplicate (LCSD) outliers occur
- No Matrix Spike outliers occur.
- No Matrix Spike Duplicate (MSD) outliers occur.
- No Test sample Surrogate recovery outliers exist.

Outliers: Reference Material (RM) Samples

- No Reference Material (RM) Sample outliers occur.

Outliers : Analysis Holding Time Compliance (Breaches)

- No Analysis Holding Time Outliers exist.

Outliers : Frequency of Quality Control Samples

- No Quality Control Sample Frequency Outliers occur.

Analysis Holding Time Compliance

This report summarizes extraction / preparation and analysis times and compares each with ALS recommended holding times, which are selected to meet known provincial and/or federal requirements. In the absence of regulatory hold times, ALS establishes recommendations based on guidelines published by organizations such as CCME, US EPA, APHA Standard Methods, ASTM, or Environment Canada (where available). Dates and holding times reported below represent the first dates of extraction or analysis. If subsequent tests or dilutions exceeded holding times, qualifiers are added (refer to COA).

If samples are identified below as having been analyzed or extracted outside of recommended holding times, measurement uncertainties may be increased, and this should be taken into consideration when interpreting results.

Where actual sampling date is not provided on the chain of custody, the date of receipt with time at 00:00 is used for calculation purposes.

Where only the sample date without time is provided on the chain of custody, the sampling date at 00:00 is used for calculation purposes.

Matrix: Water

Evaluation: × = Holding time exceedance; ✓ = Within Holding Time

Analyte Group : Analytical Method / Container / Client sample ID	ALS Sample ID	QC Lot	Method	Sampling Date	Extraction / Preparation				Analysis			
					Preparation Date	Holding Times		Eval	Analysis Date	Holding Times		Eval
						Rec	Actual			Rec	Actual	
Total Metals : Total Metals in Water by CRC ICPMS												
HDPE - total (lab preserve)												
Arsenic Plant Tank B	001	2907622	E420	14-Oct-2026	21-Oct-2026	180 days	7 days	✓	22-Oct-2026	180 days	8 days	✓

Rec. HT: ALS recommended hold time (see units).

Quality Control Parameter Frequency Compliance

The following report summarizes the frequency of laboratory QC samples analyzed within the analytical batches (QC lots) in which the submitted samples were processed. The actual frequency should be greater than or equal to the expected frequency.

Matrix: Water

Evaluation: × = QC frequency outside specification; ✓ = QC frequency within specification

Quality Control Sample Type			Count		Frequency (%)		
Analytical Methods	Method / Lab	QC Lot #	QC	Regular	Actual	Expected	Evaluation
Laboratory Duplicates (DUP)							
Total Metals in Water by CRC ICPMS	E420 / VA	2907622	1	18	5.6	5.0	✓
Laboratory Control Samples (LCS)							
Total Metals in Water by CRC ICPMS	E420 / VA	2907622	1	18	5.6	5.0	✓
Method Blanks (MB)							
Total Metals in Water by CRC ICPMS	E420 / VA	2907622	1	18	5.6	5.0	✓
Matrix Spikes (MS)							
Total Metals in Water by CRC ICPMS	E420 / VA	2907622	1	18	5.6	5.0	✓

Methodology References and Summaries

The analytical methods used by ALS are developed using internationally recognized reference methods (where available), such as those published by US EPA, APHA Standard Methods, ASTM, ISO, Environment Canada, BC MOE, and Ontario MOE. Reference methods may incorporate modifications to improve performance (indicated by “mod”).

Preparation Methods	Method / Lab	Matrix	Method Reference	Method Descriptions
Total Metals Water Digestion	EP420 ALS Environmental - Vancouver	Water	EPA 200.2 (mod)	Water samples are digested with HNO3 and HCl to liberate "total recoverable" metals.
Analytical Methods	**Method / Lab**	**Matrix**	**Method Reference**	**Method Descriptions**
Total Metals in Water by CRC ICPMS	E420 ALS Environmental - Vancouver	Water	EPA 200.2/6020B (mod)	Water samples are digested with nitric and hydrochloric acids, and analyzed by Collision/Reaction Cell ICPMS. Method Limitation (re: Sulfur): Sulfide and volatile sulfur species may not be recovered by this method.

ALS Canada Ltd.

right solutions.
right partner.

QUALITY CONTROL REPORT

Work Order	:	**KS2604214**			
Client	:	Nicola Lakeshore Water Utility Co. Ltd.	Laboratory	:	ALS Environmental - Kamloops
Contact	:	Kevin Rabbitt	Account Manager	:	Caitlin Fountain
Address	:	105 - 1121 McFarlane Way Merritt BC Canada V1K 1B9	Address	:	1445 McGill Road, Unit 2B Kamloops British Columbia Canada V2C 6K7
Telephone	:	250 378 4206	Telephone	:	250 372 3588
Project	:	Arsenic Plant B	Date Samples Received	:	14-Oct-2026 10:15
PO	:	----	Date Analysis Commenced	:	22-Oct-2026
C-O-C number	:	----	Issue Date	:	22-Oct-2026 16:52
Sampler	:	Jeff Wike, Nikki Fulford			
Site	:	Nicola Lakeshore Water Utility			
Quote number	:	Nicola Lakeshore Routine Tests			
No. of samples received	:	1			
No. of samples analysed	:	1			

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Quality Control Report contains the following information:

- Laboratory Duplicate (DUP) Report; Relative Percent Difference (RPD) and Data Quality Objectives
- Matrix Spike (MS) Report; Recovery and Data Quality Objectives
- Method Blank (MB) Report; Recovery and Data Quality Objectives
- Laboratory Control Sample (LCS) Report; Recovery and Data Quality Objectives

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is conducted in accordance with US FDA 21 CFR Part 11.

Signatories	*Position*	*Laboratory Department*
Kim Jensen	Department Manager - Metals	Vancouver Metals, Burnaby, British Columbia

General Comments

The ALS Quality Control (QC) report is optionally provided to ALS clients upon request. ALS test methods include comprehensive QC checks with every analysis to ensure our high standards of quality are met. Each QC result has a known or expected target value, which is compared against predetermined Data Quality Objectives (DQOs) to provide confidence in the accuracy of associated test results. This report contains detailed results for all QC results applicable to this sample submission. Please refer to the ALS Quality Control Interpretation report (QCI) for applicable method references and methodology summaries.

Key:
Anonymous=Refers to samples which are not part of this work order, but which formed part of the QC process lot.
CAS Number=Chemical Abstracts Service number is a unique identifier assigned to discrete substances.
DQO=Data Quality Objective.
LOR=Limit of Reporting (detection limit).
RPD=Relative Percent Difference
# =Indicates a QC result that did not meet the ALS DQO.

Workorder Comments

Holding times are displayed as "---" if no guidance exists from CCME, Canadian provinces, or broadly recognized international references.

Laboratory Duplicate (DUP) Report

A Laboratory Duplicate (DUP) is a randomly selected intralaboratory replicate sample. Laboratory Duplicates provide information regarding method precision and sample heterogeneity. ALS DQOs for Laboratory Duplicates are expressed as test-specific limits for Relative Percent Difference (RPD), or as an absolute difference limit of 2 times the LOR for low concentration duplicates within ~ 4-10 times the LOR (cut-off is test specific).

Sub-Matrix: Water

					Laboratory Duplicate (DUP) Report						
Laboratory sample ID	Client sample ID	Analyte	CAS Number	Method	LOR	Unit	Original Result	Duplicate Result	RPD(%) or Difference	Duplicate Limits	Qualifier
Total Metals(QC Lot: 2907622)											
FJ2602940-001	Anonymous	Arsenic, total	7440-38-2	E420	0.00010	mg/L	0.00143	0.00146	1.47 %	20%	---

Method Blank (MB) Report

A Method Blank is an analyte-free matrix that undergoes sample processing identical to that carried out for test samples. Method Blank results are used to monitor and control for potential contamination from the laboratory environment and reagents. For most tests, the DQO for Method Blanks is for the result to be < LOR.

Sub-Matrix: Water

Analyte	CAS Number	Method	LOR	Unit	Result	Qualifier
Total Metals(QC Lot: 2907622)						
Arsenic, total	7440-38-2	E420	0.0001	mg/L	<0.00010	----

Laboratory Control Sample (LCS) Report

A Laboratory Control Sample (LCS) is an analyte-free matrix that has been fortified (spiked) with test analytes at known concentration and processed in an identical manner to test samples. LCS results are expressed as percent recovery, and are used to monitor and control test method accuracy and precision, independent of test sample matrix.

Sub-Matrix: Water

					Laboratory Control Sample (LCS) Report				
					Spike	Recovery (%)	Recovery Limits (%)		
Analyte	CAS Number	Method	LOR	Unit	Target Concentration	LCS	Low	High	Qualifier
Total Metals(QC Lot: 2907622)									
Arsenic, total	7440-38-2	E420	0.0001	mg/L	1 mg/L	105	80.0	120	----

Matrix Spike (MS) Report

A Matrix Spike (MS) is a randomly selected intra-laboratory replicate sample that has been fortified (spiked) with test analytes at known concentration, and processed in an identical manner to test samples. Matrix Spikes provide information regarding analyte recovery and potential matrix effects. MS DQO exceedances due to sample matrix may sometimes be unavoidable; in such cases, test results for

Sub-Matrix: Water

					Matrix Spike (MS) Report					
					Spike		Recovery (%)	Recovery (%)		Qualifier
Laboratory sample ID	*Client sample ID*	*Analyte*	*CAS Number*	*Method*	*Concentration*	*Target*	*MS*	*Low*	*High*	
Total Metals(QC Lot: 2907622)										
KS2604200-001	Anonymous	Arsenic, total	7440-38-2	E420	0.0196 mg/L	0.02 mg/L	98.1	70.0	130	---

Chain of Custody (COC) / Analytical Request Form

ALS Environmental

www.alsglobal.com

Canada Toll Free: 1 800 668 9878

Affix ALS barcode label here (lab use only)

COC Number: 15 -

Page of

Report To	Contact and company name below will appear on the final report
Company:	Nicola Lakeshore Water Utility
Contact:	
Phone:	250-378-4176
	Company address below will appear on the final report
Street:	106 1121 McFarlane Way
City/Province:	Merritt, BC
Postal Code:	V1K 1B9
Invoice To	Same as Report To ☑ YES ☐ NO
	Copy of Invoice with Report ☑ YES ☐ NO
Company:	
Contact:	

Report Format / Distribution	
Select Report Format:	☑ PDF ☐ EXCEL ☐ EDD (DIGITAL)
Quality Control (QC) Report with Report	☐ YES ☐ NO
☐ Compare Results to Criteria on Report - provide details below if box checked	
Select Distribution:	☑ EMAIL ☐ MAIL ☐ FAX
Email 1 or Fax	small.companies@emconservices.ca
Email 2	tibar@telus.net, nfulford.nlwu@emconservices.ca
Email 3	katharine.mcnamara@interiorhealth.ca

Invoice Distribution	
Select Invoice Distribution:	☑ EMAIL ☐ MAIL ☐ FAX
Email 1 or Fax	small.companies@emconservices.ca
Email 2	tibar@telus.net

Project Information	Oil and Gas Required Fields (client use)	
ALS Account # / Quote #:	AFE/Cost Center:	PO#
Job #:	Major/Minor Code:	Routing Code:
PO / AFE:	Requisitioner:	
LSD:	Location:	

ALS Lab Work Order # (lab use only): 4214 **ALS Contact:** **Sampler:** Jeff Wike, Nikki Fulford

Select Service Level Below - Please confirm all E&P TATs with your AM - surcharges will apply

Regular [R] ☑ Standard TAT if received by 3 pm - business days - no surcharges apply

PRIORITY (Business Days)		EMERGENCY	
4 day [P4]	☐	1 Business day [E1]	☐
3 day [P3]	☐	Same Day, Weekend or Statutory holiday [E0]	☐
2 day [P2]	☐		

Date and Time Required for all E&P TATs:

For tests that can not be performed according to the service level selected, you will be contacted.

Analysis Request

Indicate Filtered (F), Preserved (P) or Filtered and Preserved (F/P) below

ALS Sample # (lab use only)	Sample Identification and/or Coordinates (This description will appear on the report)	Date (dd-mmm-yy)	Time (hh:mm)	Sample Type	Arsenic Only	Number of Containers
	Arsenic Plant Tank B	14-Oct-26	7:30	Water	X	1

Environmental Division Kamloops
Work Order Reference
KS2604214

Telephone : +1 250 372 3588

Drinking Water (DW) Samples[1] (client use)

Are samples taken from a Regulated DW System? ☐ YES ☐ NO

Are samples for human drinking water use? ☑ YES ☐ NO

Special Instructions / Specify Criteria to add on report by clicking on the drop-down list below (electronic COC only)

SAMPLE CONDITION AS RECEIVED (lab use only)

Frozen ☐ SIF Observations Yes ☐ No ☐

Ice Packs ☑ Ice Cubes ☐ Custody seal intact Yes ☐ No ☐

Cooling Initiated ☐

INITIAL COOLER TEMPERATURES °C			FINAL COOLER TEMPERATURES °C		
16					

SHIPMENT RELEASE (client use)			INITIAL SHIPMENT RECEPTION (lab use only)			FINAL SHIPMENT RECEPTION (lab use only)		
Released by: Bhanu Pratap	Date: 14-Oct-26	Time:	Received by:	Date: OCT 14 2026	Time: 1015	Received by:	Date:	Time:

REFER TO BACK PAGE FOR ALS LOCATIONS AND SAMPLING INFORMATION


Failure to complete all portions of this form may delay analysis. Please fill in this form LEGIBLY. By the use of this form the user acknowledges and agrees with the Terms and Conditions as specified on the back page of the white - report copy.

WHITE - LABORATORY COPY YELLOW - CLIENT COPY

1. If any water samples are taken from a **Regulated Drinking Water (DW) System**, please submit using an **Authorized DW COC form**.

OCTOBER 2015 FRONT

NLSWU ARSENIC LEVELS 2026



	Jan-26	Feb-26	Mar-26	Apr-26	May-26	Jun-26	Jul-26	Aug-26	Sep-26	Oct-26	Nov-26	Dec-26	
Reading	0.00676	0.00655	0.00632	0.00663	0.00680	0.00784	0.00866	0.00900	0.00930	0.01060			
MAC	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	