



# Nicola Lakeshore Water Utility Co. Ltd.

---

January 29, 2010

VIA FAX NO. 250-851-7341

Interior Health  
519 Columbia Street  
Kamloops, BC V2C 2T8

**RE: MONTHLY REPORT FOR JANUARY 2010**

The water consumption on the Nicola Lakeshore Development for January was approximately 25,300 gallons of potable water.

Our weekly testing for water quality has shown that our supply continues to be in compliance with the Canadian Drinking Water Standards. Our more extensive tests for arsenic have now moved to monthly, after consistent results below provincially set targets.

The issue of seasonal use continues to cause us operational problems, but it appears our program is settling down to produce standard results.

We continue to provide test results on our web page at <http://nicolaestates.com/owners.html>.

Our contract operators have recently attended the Small Water Provider Seminar in Kamloops. They are scheduled to take the Fire Hydrant Service Training course in Kelowna in the next two months.

On November 27, 2009, the Utility inspected and sealed meters and looked for possible areas of cross-contamination. This process will now be an annual process.

Yours truly,

F.K. Rizzardo, A.Sc.T., GSC  
President  
250-378-4176 (Ext 309)

/ns

---

1121 McFarlane Way, Unit #106  
Merritt, B.C. V1X 1B9  
Phone (250) 378-4176 Fax (250) 378-4106