



Nicola Lakeshore Estates Inc.

June 10, 2008

TO ALL LOT OWNERS AT NICOLA LAKESHORE ESTATES

After a long process working with Interior Health and not having a failed water report since August 2007, we are happy to advise that the Boil Water Notice is now rescinded. Attached please find a copy of the letter from Interior Health.

We thank you for your patience and understanding.

Yours truly,

A handwritten signature in black ink, appearing to read 'F. R. Rizzardo', written over a light blue horizontal line.

F. R. Rizzardo, A.Sc.T.
Managing Director

/bt

Attachment

1121 McFarlane Way, Unit #106
Merritt, B.C. V1K 1B9
Phone (250) 378-4176 Fax (250) 378-4106



Interior Health

June 6, 2008

Nicola Lakeshore Water Utility Co. Ltd.
Unit 106 - 1121 McFarlane Way
Merritt, BC V1K 1B9

Attention: Frank Rizzardo, President

Dear Sir:

Re: Rescinding of Boil Water Notice, Nicola Lakeshore Water Utility Co. Ltd.

On June 5, 2008 Interior Health conducted a site visit and review of the above water system. Based on this review the following is noted:

1. All water samples submitted after August 7, 2007 have consistently tested negative for the presence of bacteria.
2. The TRUE Consulting assessment of the water system, dated December 20, 2007 addresses Interior Health concerns regarding low chlorine residual and cross connection potential. The assessment determined that the water is treated adequately to protect the water users and that no cross connections existed between the non-potable Irrigation system and the potable water system.
3. The water system operators have initiated steps to maintain higher chlorine residuals in the distribution system by:
 - a. Increasing water flows in the system by having valves at the ends of the distribution system opened more often, and
 - b. Maintaining a lower level of water in the reservoirs.

Based on the above, the Boil Water Notice applied to the Nicola Lakeshore Water Utility water system on August 10, 2007 is rescinded.

If you have any questions regarding this matter please contact our office at 250-851-7340.

Sincerely,

Ted Mahler
Registered Public Health Inspector/
Drinking Water Officer

Bus: (250) 851-7349 Fax: (250) 851-7341
Email: ted.mahler@interiorhealth.ca
Web: Interiorhealth.ca

HEALTH PROTECTION
"Less Risk, Better Health"
519 Columbia St, Kamloops, BC, V2C 2T8