



# Nicola Lakeshore Water Utility Co. Ltd.

July 7, 2009

VIA FAX NO. 250-851-7341

Interior Health  
519 Columbia Street  
Kamloops, BC V2C 2T8

Attention: Rob Fleming for Claire Audet

**RE: MONTHLY REPORT – JUNE 2009**

All testing done in June passed the Canadian Water Standards. In June, 50 users connected to the system used 260,000 gallons of potable water. We still have three users who have electrical malfunctions between the transponder and the water meter. All three have been advised of the malfunction and at the end of July, if no repair is done, their water will be shut off.

The water filter plant has been up and running with a minor hick up on PH and as a result, arsenic level fluctuation has occurred in the month. We have made corrections to settings and are awaiting test results.

Two additional meters and transponders were sold in June for houses under construction and one service connection inspection was carried out.

Our operator also contracted with a prominent pump supplier to update the chlorine pumps at the center well. The new pump will have capacity to be monitored at the operations building via communications cable that was installed for the water well pumps.

Yours truly

F. R. Rizzardo, A. Sc. T.  
President  
250-378-4176 (Ext 309)

/bt

---

1121 McFarlane Way, Unit #106  
Merritt, B.C. V1K 1B9  
Phone (250) 378-4176 Fax (250) 378-4106